




Nebraska State Fire Marshal Inspection Report

Facility Name	Fascination
Address	520 N Washington St, Lexington, NE
ZIP	68850
Facility Phone Number	
Inspector Name	
Inspector Badge#	--
Inspector Agency	--
Inspector Email	--
Inspector Phone Number	--
Number of Visits	
Date of Inspection	2023-04-26
Inspection Type	Revisit
Status	Failed
Complete Corrections By	
Occupant Load	50
Fee Card	N/A
Fee Sheet/Facility ID Number	
Code Reviews	

Inspectors and Operator Staff Involved			
Lead Inspector	Badge #	Agency	Phone Number
	--	--	--

All items must be corrected to comply with the laws of the State of Nebraska and with rules and regulations adopted by the State Fire Marshal as mandated by section 81-502 to 81-541.01. It is the duty of the owner or person in charge of the above-named facility to immediately take measures to bring the facility into compliance with state regulations. ALL CORRECTIONS SHALL BE MADE AND ALL ITEMS CORRECTED ON OR BEFORE undefined

If you have questions on this Order, contact undefined by phone at -- or by Email at --

Inspector Comments / Notes	
Report completed by Deputy	Michael Hoeft
Date Signed	2023-04-26
Signature	

Inspection Violations

Failed Item	Status	Code
New Assembly		
7. Means of egress. General Minimum of two exits shall be provided	Fail	See below code 12.2
29. Number of means of egress	Fail	See below code 12.2.4*
30. Arrangement of means of egress	Fail	See below code 12.2.5.1.1
44. Emergency Lighting Emergency lighting units shall be repaired or replaced to work properly	Fail	See below code 12.2.9

Inspection Code Reference

- 12.2 - 2012 ed - *Means of Egress Requirements.*
- 12.2.4* - 2012 ed - *Number of Means of Egress.*
- 12.2.5.1.1 - 2012 ed - *Means of egress shall be arranged in accordance with Section 7.5.*
- 12.2.9 - 2012 ed - *Emergency Lighting.*